

Occupancy	W.C.		Urinals	Sinks		Drinking fountains	Tubs or showers	Others appliances
	gentlemen	ladies		gentlemen	ladies			
Arenas								
Players	1/30 players		1/30 players	1/30 players		1/60 players	1/10 players	
Spectators	1/600 men	3/600 women	2/600 men	2/600 men	2/600 women	1/600 spectators		
Building under Construction								
1 to 210 employees	1/30 employees			see (b)				
211 +	see (a)			see (b)				
Brasseries	1/40 customers	1/90 customers	see (c)	1/80 customers	1/180 customers			
Physicians, dentists and other health practitioners officers	1			2				
				see (d)				
Cinemas, theatres, auditoriums, exhibition and convention halls								
1 to 100 persons	1	1		1	1	1		one service tub
101 to 200 persons	2	2		1	1	1		
201 to 400 persons	3	3	see (e)	2	2	1		
401 to 750 persons	add 1/600 persons	add 1/600 persons		3	3	2		see (***)
751 up				add 1/1000 persons	add 1/1000 persons	add 1/1000 persons		
employees: see (f)								
Medical clinic	1/floor	1/floor		1/floor	1/floor	1/floor		

**NOTES:**

- (a) Above 210 employees, the sanitary accommodations shall be determined by the inspector.
- (b) Sinks are compulsory if employees have to handle corrosive, noxious or irritating substances.
- (c) 2/3 of men W.C. may be replaced by urinals.
- (d) A sink shall be installed in the examination room in addition to the one in the toilet room.
- (e) For men, half the compulsory W.C. may be replaced by urinals.
- (f) Sanitary accommodations for employees shall be the same as those required for office building.

Bars (holding a permit from the Régie des permis d'alcool du Québec)								
Patrons:	1/25	1/30		1/50	1/60			
Employees: see (f)	men	women	see (c)	men	women			
Dormitories, boarding								
houses for children	1/10	1/8	1/25	1/12	1/12	1/75 persons	see (g) 1/8 persons	one tub for 50 people
1 to 150 persons	men	women	men	men	women			one sink or service tub
151 persons up	add 1/10	add 1/8	add 1/50	add 1/12	add 1/12	1/75 persons	add 1/20 persons	for 100 people see (***)
School								
(1) primary	1/40	1/35	1/30	1/50	1/50	see (h)	see (i)	one service tub for 1/floor
	boys	girls	boys	boys	girls	1/100 pupils	1/5 pupils	
(2) others	1/75	1/45	1/30	1/50	1/50	1/100 pupils	1/5 pupils	for 1/floor
	boys	girls	boys	boys	girls			
(3) Teachers: see (f)								see (***)
Office buildings								
see (j)						see (k)		
1 to 15 empl. of each sex	1	1		1	1	1/75 employees		one service tub per floor
16 to 35 empl. of each sex	2	2	see (e)	2	2			
36 to 60 empl. of each sex	3	3		2	2			
61 to 80 empl. of each sex	4	4		3	3			
81 to 90 empl. of each sex	5	5		3	3			
91 to 110 empl. of each sex	5	5		4	4			
111 to 125 empl. of each sex	6	6		4	4			
126 up empl. of each sex	add 1/50	add 1/50		add 1/60	add 1/60			see (***)
	men	women		men	women			

**NOTES:**

- (g) In a girls dormitory , tubs shall be added in the proportion of 1/30.  
(h) At least one per floor.  
(i) In the gymnasium and according to the largest group using it.  
(j) Only one toilet room is compulsory for 10 employees or less of both sexes.  
(k) A drinking fountain is not required for less than 5 employees.

Churches, chapels Places of worship	1/300 men	1/150 women	1/300 men	1/300 men	1/300 women	
Sentry-box, shelter temporary building see (l)		1			1	
Hospital Centers						
(1) private room		1		1		One service tub per floor
(2) communal room	1/8 patients		1/8 patients		1/100 patients	for the first
(3) waiting room		1		1	1/20 patients	50 patients
(4) employees: see (f)						and an additional tub for each
						50 additional patients or important percentage thereof see (***)
Hotel – Motel	see (m)			see (n)		
(1) private room	1/ room			1/ room		1/room
(2) rooms with common bathroom:						
1 to 4 rooms/floor	1/floor			1/floor		1/floor
5 to 8 rooms/floor	1/floor add	1/floor add		1/floor add	1/floor add	1/sex add
9 rooms up/floor	1/8 rooms	1/8 rooms		1/8 rooms	1/8 rooms	1/8 rooms for each sex
Personal and professional care institutes, hairdressing salons and barber shops	1	1		1	1	1 shower
				1/care units		see (o)

**NOTES:**

- (l) A W.C. and a sink shall be installed, unless written permission is given to use to washroom situated within a maximum of 100 feet.
- (m) General access washroom be separated from bathrooms and sink.
- (n) A sink is compulsory for each room not equipped with a private bathroom.
- (o) A shower for each massage, physiotherapy or similar treatment unit.
- (p) One tub per apartment or connections for automatic washing machine.
- (q) A double tub for every 10 apartments or an automatic washing machine for every 20 apartments.

<b>Apartments</b>							
1 to 7 units	1/apartment		1/apartment			1 tub/ apartment	1 sink per apartment see (p)
8 units up	1/apartment		1/apartment			1 tub/ apartment	1 sink per apartment see (q)
<b>Stores</b>							
(a) retail see (r)	1		1			see (s)	
(b) department, shopping centres							
(1) customers	1/300	1/300	see (e)	1/300	1/300	1/300	see (s)
(2) employees: see (f) (t)	men	women		men	women	customers	
<b>Rooming house</b>							
(tourist, furnished, boarding, homes)	see (m)		see (n)			see (u)	
	1/10	1/10		1/10	1/10		2/10
	rooms	rooms		rooms	rooms		rooms
<b>Pools</b> see (v)							
(1) indoor	1/60	1/40	1/60 men	1/100	1/100	1/100	1/40
	men	women		men	women	swimmers	swimmers
(2) outdoor	1/20	1/80	1/120 men	1/300	1/300	1/100	1/80
	men	women		men	women	swimmers	swimmers
(3) spectators	1/600	3/600	2/600 men	2/600	2/600	1/100	
	men	women		men	women	spectators	

**NOTES:**

- (r) Several stores may share a common washroom on condition that this washroom is accessible from the inside.
- (s) A tub or sink shall be installed in a food store.  
In dog kennels and petshops a tub or a service sink and a floor drain shall be installed.
- (t) Appliances for employees may be situated in the customers washroom.
- (u) In old people's homes, bathtubs shall be installed in the proportion of 1 for 10 persons.
- (v) Rooms are so arranged that swimmers must go through the water closet to get to the showers.

---

Jails, prisons

- (1) inmates: see (w)  
(2) employees: see (f)
- 

Restaurants

1 to 25 customers	1	see (x)	1	see (x)	-
26 to 50 customers	1 see (x)	1 see (x)	1 see (x)	1 see (x)	
51 to 100 customers	1	2	1	1	
101 to 150 customers	1	2	see (e)	1	2
151 to 200 customers	2	3		2	2
201 to 300 customers	3	3		3	3
301 up customers	add	add	add	add	
	1/50	1/50	1/50	1/50	
	men	women	men	women	

Employees: see (f) and (y)

---

Reception rooms,  
meeting halls

(holding a permit from  
the Société des alcools  
du Québec)

Customers

	1/30	1/30	1/60	1/60	1/1000	see (***)
	men	women	men	women	customers	one tub or service sink

---

Funeral homes

1	1	1	1	1	1	one service sink and one floor drain in the embalming room see (***)
---	---	---	---	---	---	--

---

**NOTES:**

- (w) According to the requirements of the provincial or federal authorities.
- (x) Under 26 customers, 1 W.C. and 1 sink will be enough for both customers and employees.  
From 26 to 50 customers, 2 W.C. and 2 sinks will be enough for both customers and employees, but in 2 separate washrooms.  
When customers eat outside, separate washrooms for both sexes with access to the outside are compulsory.
- (y) A washroom is not required for less than 5 employees.

Service station gas bar see (z)	1	1		1	1	
Plants, factories, warehouses, foundries, workshops, food processing, laundries see (j)						see (h) and (k) see (aa)
1 to 10 empl. of each sex	1	1		1 add 1/10 men	1 add 1/10 women	
11 to 25 empl. of each sex	2	2	1			
26 to 50 empl. of each sex	3	3	2			one unit by 75 employees
51 to 75 empl. of each sex	4	4	2			
76 to 100 empl. of each sex	5	5	3			
101 up empl. of each sex	add 1/50 men	add 1/50 women	add 1/90 men	add 1/15 men	add 1/15 women	

**NOTES:**

(z) Separate rooms with access to the outside compulsory for both sexes.

(aa) A shower is compulsory for 15 employees exposed to excessive heat or to skin contact with corrosive, noxious or irritating substances.

(\*\*\*) The service tub may have a 50 millimetre diameter drain outlet if the floor is covered with a carpet.

The service sink may be replaced by a service tub.