

Tank capacity (litres)	Product	Minimum distance, in metres, measured horizontally, between any point on outside tank shell and		
		Dike centre line when required by sections 8.60 and 8.61	Closest building	Property line
2,000 to 5,000	Class 1	D	D	D
5,001 to 47,000	Classes 2 and 3	0.5	0.5	1.5
	Class 1	D	D	D
	Classes 2 and 3*	1.5	1.5	1.5
	Class 3 — flash point above 93.3 °C	0.5	0.5	1.5
47,001 to 200,000	Class 1	D	D	D
	Classes 2 and 3*	D	D	D
	Class 3 — flash point above 93.3 °C	1	1	D
200,001 to 400,000	All	D	5	5
400,001 to 2,000,000	All	D	9	9
2,000,001 to 4,000,000	All	D	12	12
More than 4,000,000	All	D	15	15

D: The greater distance between 3 m and one-half tank height. Tank height is measured from the bottom of the diked areas.

* Class 3 products are products with a flash point not above 93.3 °C.