

TABLE I

**SEASONAL CLOUD POINTS OF DIESEL FUELS CONFORMING TO THE AVERAGE 2.5% LOW-END DESIGN TEMPERATURES FOR THE USE ZONES ILLUSTRATED IN FIGURE I (TEMPERATURES IN DEGREES CELSIUS)**

PERIODS	USE ZONES									
	1	2	3	4	5	6	7	8	9	10
	Montréal	Abitibi, hautes Laurentides Saguenay	Québec & Bas- du-Fleuve	Estrie	Est du Québec & Gaspésie	Côte Nord	Baie-James & Nord du Québec	Nunavik	Laurentides & Outaouais*	Îles-de-la- Madeleine
Jan. 1-15	-25	-35	-27	-30	-27	-30	-36	-39	-29	-16
Jan. 16-31	-26	-35	-28	-29	-28	-30	-37	-39	-30	-19
Feb. 1-14	-25	-33	-27	-27	-28	-30	-37	-39	-28	-20
Feb. 15-28	-22	-31	-25	-24	-25	-27	-36	-37	-26	-17
March 1-15	-18	-27	-20	-23	-22	-25	-34	-36	-24	-15
March 16-31	-13	-23	-16	-16	-18	-21	-30	-32	-18	-11
April 1-15	-6	-17	-10	-10	-10	-15	-24	-26	-10	-5
April 16-30	-2	-9	-4	-5	-6	-8	-20	-23	-5	-2
May 1-15	1	-5	-2	-2	-2	-3	-11	-13	-2	0
May 16-31	4	-2	1	1	0	-2	-6	-8	1	3
June 1-15	7	1	4	4	2	1	-2	-3	3	5
June 16-30	10	4	6	7	5	3	0	-1	6	8
July 1-15	12	6	8	8	7	6	2	2	7	10
July 16-31	11	7	9	9	9	7	4	3	8	12
Aug. 1-15	10	6	8	9	8	5	4	4	7	14
Aug. 16-31	8	4	6	6	6	4	2	3	5	12
Sept. 1-15	5	1	4	3	3	2	1	1	2	10
Sept. 16-30	2	-2	1	0	0	-1	-2	-2	-1	7
Oct. 1-15	-1	-4	-2	-3	-3	-3	-6	-6	-3	4
Oct. 16-31	-4	-7	-4	-5	-4	-5	-10	-9	-6	1
Nov. 1-15	-7	-14	-9	-10	-9	-11	-18	-18	-10	-1
Nov. 16-30	-11	-19	-14	-14	-15	-19	-23	-24	-15	-5
Dec. 1-15	-20	-27	-22	-22	-22	-25	-31	-32	-24	-10
Dec. 16-31	-22	-32	-24	-25	-25	-28	-35	-38	-27	-12

\* Except within the limits of Ville de Gatineau where the cloud points for use zone No. 1 (Montréal) apply, with the exception of the periods between 16 to 31 January, 1 to 14 February, 15 to 28 February and 16 to 31 March for which the maximum cloud points to conform to are respectively -25°C, -22°C, -21°C and -12°C.

## Notes:

1. Seasonal cloud points conform to low-end design temperatures retained on 27 June 2013 from Environment Canada data for the Canadian General Standards Board. They cover the period from 1980 to 2010.
2. Use zones correspond to the zones in Figure I.
3. Cloud points differing as to storage and use conditions may be specified in a written agreement between the user and the supplier.

**FIGURE I**

**Use zones for the various diesel fuels**  
 (According to the average 2.5% low-end design temperatures)

